

File H080674 - Document CEMATE/9 - Page 1/4

**EUROPEAN REACTION TO FIRE CLASSIFICATION REPORT
ACCORDING TO THE EUROPEAN STANDARD EN 13501-1**

Notified Body by the French State besides the European Commission under number : 0071

Product standard : NF EN 14041
Resilient, textile and laminate floorcoverings

(free translation of French classification report n° H080674 CEMATE/8)

N°H080674 - CEMATE/9

Material submitted by : GERFLOR SA
50 Cours de la République
69627 VILLEURBANNE CX
FRANCE

Commercial trademark : MIPOLAM 150 (2 mm) / MIPOLAM 180 PUR (2 mm)

Brief description : PVC floorcovering

Date of report : 2007, September 25th

**Only full reproduction of the present document is authorized.
It contains 4 pages**

1. INTRODUCTION

This classification report defines the classification assigned to product in accordance with the procedures given in EN 13501-1.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. NATURE AND END USE APPLICATION

Type VFHO, PVC floorcovering (NF EN 649 standard).

2.2. DESCRIPTION

Product characteristics:

Trademark	Composition	Mass per unit square meter	Thickness
MIPOLAM 150 (2 mm) MIPOLAM 180 PUR (2 mm)	PVC Plasticizers Fillers	3360 (-10/+13 %) g/m ²	2.00 (-0.10/+0.13) mm

Fireproofing : no

Informations given by the sponsor

Text report to be followed on next page

3. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1. TEST REPORTS

Name of laboratory	Name of sponsor	Test report ref. n°	Test method
Laboratoire national de métrologie et d'essais 29 av. Roger Hennequin 78197 TRAPPES CEDEX	GERFLOR SA 50 Cours de la République 69627 VILLEURBANNE CX FRANCE	File : H080674 CEMATE/7	Radiant panel EN ISO 9239-1

3.2. TEST RESULTS FOR FLOORINGS

Test method	Number of tests	Parameters	Results
NF EN ISO 9239-1	1 (5 specimens)	Critical flux (kW/m ²) Smoke (%.min)	≥ 11 54

Text report to be followed on next page

4. CLASSIFICATION AND DIRECT FIELD APPLICATION

4.1. CLASSIFICATION

Fire behaviour	Smoke production	Flaming droplets
B_{fl}	S1	-

4.2. FIELD OF APPLICATION

This classification is valid for the products mentioned in § 2.2 or strictly and equally stipulated in the quoted production site noted in the test report.

Colour : various

Thickness : about 2 mm

Glued with an acrylic adhesive to A1fl or A2fl classified substrates

5. LIMITATIONS

5.1. RESTRICTIONS CONCERNING THE VALIDITY PERIOD OF THE CLASSIFICATION REPORT

None.

5.2. WARNING

This document does not represent type approval or certification of the product.

Trappes, the 25th of September 2007

The Head of Fire Behaviour Division

Test officer



Alain SAINRAT



Emilie COLIN