

Emission Test Certificate

Friday July 16th, 2021

Supplier: Gerflor Australasia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Mipolam Concept 2.0mm Vinyl Sheet

Date Tested: July 2021 (Tested through FORAY Laboratories - NATA Accreditation 1231)


Test Method: ASTM D5116:2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products".

Emission Data (24 hrs exposure):

<p align="center">Green Building Council of Australia Green Star Design & As Built V1.3 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.1.2B</p>	<p align="center">Mipolam Concept 2.0mm Vinyl Sheet</p>
<p>Total Volatile Organic Compound Emission Rate limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$</p>	<p>Total Volatile Organic Compound Emission Rate: $0.011 \text{ mg/m}^2/\text{hr}$</p>
<p>Formaldehyde Emission Rate limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$</p>	<p>Formaldehyde Emission Rate: $< 0.006 \text{ mg/m}^2/\text{hr}$</p>
<p align="center"><i>We hereby certify that Mipolam Concept Vinyl Plank meets with requirements of Green Star Design & As Built – Green Star Interiors, Green Building Council of Australia.</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Srikanth C. Srivatsa
PhD (Chemistry)
Scientific Consultant



Dr. Tuan Duong
PhD, B Eng. (Chemical)
Senior Consultant

V2107009