

REACTION TO FIRE CLASSIFICATION REPORT N° 2025/087-2

According to EN 13501-1 (2018)

(English version of classification report N°2025/087-1)

Notification by the French Government to the European Commission under n° NB 2401

Regulation (UE) n° 305/2011

Sponsor:

GERFLOR

1 Place Verrazzano 69258 LYON Cedex 09

FRANCE

Product name:

MIPOLAM EVERCARE site 08

Description:

Polyvinyl chloride floor coverings (EN ISO 10581 family)

(see detailed description in paragraph 2)

Date of issue:

21/05/2025

The indicated classification does not prejudge the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law.

The reproduction of this classification report is only authorised in its integral form. It contains 4 pages

N°2025/087-2

1. Introduction

This classification report defines the classification assigned to the above-mentioned products in accordance with the procedures given in the NF EN 13501-1 (2018).

2. Details of classified product

2.1. Product standard

NF EN 14041 (2005): "Resilient, textile and laminate floor coverings - Essential characteristics".

2.2. Product description

Homogeneous polyvinyl chloride floor covering (EN ISO 10581 family).

Tested glued (acrylic glue BOSTIK MIPLAFIX 800 with deposing 300 g/m²) over a wood panel particle board without flame retarded classified C_{fl} -s1 with a density (680 \pm 50) kg/m³ and thickness (20 \pm 2) mm.

Use surface: Plasticized PVC Backing type: Plasticized PVC

Nominal mass per unit area : 2630 to 3300 g/m^2

Nominal total thickness: 1,5 to 2,5 mm

3. Test reports and tests results in support of this classification

3.1. Tests reports

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	GERFLOR 1 Place Verrazzano 69258 LYON Cedex 09 FRANCE	RL 2017/259 RL 2025/254 RL 2025/255	NF EN ISO 9239-1

3.2. Tests results

Classes of reaction to fire for resilient floor coverings, classified without further testing.

Test method	The floorings « MIPOLAM 150 » - « MIPOLAM 180 » - « MIPOLAM STYL » meet the
NF EN ISO 11925-2	requirements of table 3 of the standard NF EN 14041 (2005) and are classified Eff
	without further testing (CWFT)

				Results
Test method	Product	Number of tests	Parameters	Continuous parameters: mean value
NF EN ISO 9239-1	MIPOLAM 150	3	Critical heat flux (kW/m²)	≥ 11
			Smoke (% X min)	38,8

				Results
Test method	Product	Number of	Parameters	Continuous
		tests		parameters :
		tests		mean value
NF EN ISO 9239-1	MIPOLAM 180	3	Critical heat flux (kW/m²)	≥ 11
			Smoke (% X min)	66,7

				Results
Test method	Product	Number of tests	Parameters	Continuous parameters : mean value
NF EN ISO 9239-1	MIPOLAM STYL	3	Critical heat flux (kW/m²)	9,6
		3	Smoke (% X min)	394,6

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1 (2018).

4.2. Classification

Fire behaviour	Smoke produc	
B _{fl}	-	s1

Classification: $B_{fl} - s1$

4.3. Field of application

This classification is valid for the following end use applications:

Glued over a wood panel particle board without flame retarded classified C_{fl} -s1 with a density $\geq 510 \text{ kg/m}^3$ and over a fibre-cement $A1_{fl}$ or $A2_{fl}$ class with a density $\geq 1350 \text{ kg/m}^3$.

This classification is valid for the following product parameters:

A nominal mass per unit area of: 2630 to 3300 g/m²

• A nominal thickness of: 1,5 to 2,5 mm

The classification of the product family is valid for the following trademarks:

MIPOLAM ACTION
MIPOLAM AMBIANCE ULTRA
MIPOLAM ATLAS
MIPOLAM BIOCONTROL PURE
MIPOLAM COMET PLUS
MIPOLAM CONCEPT
MIPOLAM GALAXY 600
MIPOLAM GALAXY 700
MIPOLAM GALAXY 800
MIPOLAM ROUBUST EL7

MIPOLAM STYL MIPOLAM TROPAN PLUS MIPOLAM 150 MIPOLAM 180 MIPOLAM 200 PRO

5. Limitations

This classification document does not represent type approval or certification of the product.

"The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 of AVCP and CE marking under the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of constructions products.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested."

For the SARL C.R.E.T. The Technical Director Marc WELCOMME

End of the classification report