



REACTION TO FIRE CLASSIFICATION REPORT N°2018/064-2

According to EN 13501-1 (2007) + A1 (2013) + EN 13501-1 (2018)

(English version of classification report N°2018/064-1)

Notification by the French Government to the European Commission
under n° NB 2401
Regulation (UE) n° 305/2011

Sponsor :	GERFLOR 1 Place Verrazzano 69258 LYON Cedex 09 FRANCE
Product name :	PREMIUM COMPACT - PREMIUM ZERO COMPACT
Description :	Polyvinyl chloride floor coverings (EN ISO 10582 family) (see detailed description in paragraph 2)
Date of issue :	06/06/2025 (update of classification report 2018/064-2 of 17/08/2018)

The indicated classification does not prejudice the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law.

*The reproduction of this classification report is only authorised in its integral form.
It comprises 4 pages*

1. Introduction

This classification report defines the classification assigned to the above-mentioned products in accordance with the procedures given in the NF EN 13501-1 standard: September 2007 & A1 (2013) + NF EN 13501-1 (2018).

2. Details of classified product

2.1. Product standard

NF EN 14041 (2005): "Resilient, textile and laminate floor coverings - Essential characteristics".

2.2. Product description

Heterogeneous polyvinyl chloride floor covering (EN ISO 10582 family).

Tested loose laid over a wood panel particle board without flame retarded classified C_s-s1 with a density (680 ± 50) kg/m³ and thickness (20 ± 2) mm.

Use surface : PVC plastic

Backing type : PVC foam

Nominal mass per unit area : 2480 to 2650 g/m²

Nominal total thickness : 2,0 mm

Nominal wear layer thickness : 0,92 to 1,27 mm

3. Test reports and tests results in support of this classification

3.1. Tests reports

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	GERFLOR 1 Place Verrazzano 69258 LYON Cedex 09 FRANCE	RL 2018/190	NF EN ISO 9239-1

3.2. Tests results

Classes of reaction to fire for resilient floor coverings, classified without further testing.

Test method NF EN ISO 11925-2	The flooring « PREMIUM COMPACT – PREMIUM ZERO COMPACT » meets the requirements of table 3 of the standard NF EN 14041 (2005) and is classified E _n without further testing (CWFT)
----------------------------------	---

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	PREMIUM COMPACT – PREMIUM ZERO COMPACT	3	Critical heat flux (kW/m ²)	9,1
			Smoke (% X min)	241,2

4. Classification and field of application**4.1. Reference of classification**

This classification has been carried out in accordance with NF EN 13501-1 :2007 & A1 (2013)
– NF EN 13501-1 (2018).

4.2. Classification

Fire behaviour		Smoke production
B_{fl}	-	s1

Classification : B_{fl} – s1

4.3. Field of application

This classification is valid for the following end use applications :

Loose laid and glued over a wood panel particle board without flame retarded classified C_{fl}-s1 with a density $\geq 510 \text{ kg/m}^3$ and over a fibre-cement A1_{fl} or A2_{fl} class with a density $\geq 1350 \text{ kg/m}^3$.

This classification is valid for the following product parameters :

- A nominal mass per unit area of : 2480 to 2650 g/m²
- A nominal thickness of : 2,0 mm
- A nominal wear layer thickness of : 0,92 to 1,27 mm

The classification of the product family is valid for the following trademarks :

Brazilia
Cocoon
Costa Rica
Forum
Fusion
Indiana
Metallica
Neopolis
Neoterra
Ozmoz
Poesy

5. Limitations

This classification document does not represent type approval or certification of the product.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 of AVCP and CE marking under the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of constructions products.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.”

This classification document does not represent type approval or certification of the product.

For the SARL C.R.E.T.
The Technical Director
Marc WELCOMME



End of the classification report