

REACTION TO FIRE CLASSIFICATION REPORT N°2025/151-2

According to EN 13501-1 (2018)

(English version of classification report N°2025/151-1)

Notification by the French Government to the European Commission under n° NB 2401

Regulation (UE) n° 305/2011

Sponsor:

GERFLOR

1 Place Verrazzano

69258 LYON Cedex 09

FRANCE

Product name:

CREATION DECO range (035)

Description:

Polyvinyl chloride floor coverings (EN ISO 10582 family)

(see detailed description in paragraph 2)

Date of issue:

05/09/2025

The indicated classification does not prejudge the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law.

The reproduction of this classification report is only authorised in its integral form. It contains 4 pages

1. Introduction

This classification report defines the classification assigned to the above-mentioned products in accordance with the procedures given in the NF EN 13501-1 (2018).

2. Details of classified product

2.1. Product standard

NF EN 14041 (2005): "Resilient, textile and laminate floor coverings - Essential characteristics".

2.2. Product description

Heterogeneous polyvinyl chloride floor covering (EN ISO 10582 family).

Tested glued (acrylic glue with deposing 300 g/m²) over a wood panel particle board without flame retarded classified C_{fl} -s1 with a density (680 ± 50) kg/m³ and thickness (20 ± 2) mm.

Use surface: Plasticized PVC

Backing type: PVC

Nominal mass per unit area : 3430 to 4410 g/m² Nominal total thickness : 2,00 to 2,50 mm Nominal wear layer thickness : 0,30 to 0,70 mm

3. Test reports and tests results in support of this classification

3.1. Tests reports

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	GERFLOR	RL 2025/547	NF EN ISO 9239-1
	1 Place Verrazzano	RL 2025/548-1	(EN ISO 9239-1: 2010)
	69258 LYON Cedex 09	RL 2025/548-2	NF EN ISO 11925-2
	CEDEX		(EN ISO 11925-2: 2020)

3.2. Tests results

Classes of reaction to fire for resilient floor coverings, classified without further testing.

Test method	The flooring « CREATION 30 DECO » meets the requirements of table 3 of the
NF EN ISO 11925-2	standard NF EN 14041 (2005) and is classified E _{fl} without further testing (CWFT)

			Results	
Test method	Product	Number of tests	Parameters	Compliance parameters
NF EN ISO 11925-2	CREATION 70 DECO	6	Fs ≤ 150 mm	Compliant
Surface exposure-15 secondes			Ignition of the filter paper	Compliant

				Results
Test method	Product	Number of tests	Parameters	Continuous parameters: mean value
NF EN ISO 9239-1	CREATION 30 DECO	3	Critical heat flux (kW/m²)	10,8
			Smoke (% X min)	96,6

				Results
Test method	Product	Number of tests	Parameters	Continuous parameters: mean value
NF EN ISO 9239-1	CREATION 70 DECO	3	Critical heat flux (kW/m²)	10,2
			Smoke (% X min)	175,5

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1 (2018).

4.2. Classification

Fire behaviour		Smoke production
${f B_{fl}}$	-	s1

Classification: B_{fl}-s1

4.3. Field of application

This classification is valid for the following end use applications:

Glued over a wood panel particle board without flame retarded classified C_{fl} -s1 with a density $\geq 510 \text{ kg/m}^3$ and over a fibre-cement $A1_{fl}$ or $A2_{fl}$ class with a density $\geq 1350 \text{ kg/m}^3$.

This classification is valid for the following product parameters:

- A nominal mass per unit area of: 3430 to 4410 g/m²
- A nominal thickness of: 2,00 to 2,50 mm
- A nominal wear layer thickness of 0,30 to 0,70

The classification of the product family is valid for the following trademarks:

CREATION 30 DECO CREATION 40 DECO CREATION 55 DECO CREATION 70 DECO

5. Limitations

This classification document does not represent type approval or certification of the product.

"The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 of AVCP and CE marking under the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of constructions products.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested."

For the SARL C.R.E.T. The Technical Director Marc WELCOMME

End of the classification report